

Chart showing the temperature before and after fitting a Ground-Air Heat Exchanger

Month	Temperature °C before	Temperature °C after
Sep-09	17.6	15.3
Oct-09	13.9	13.9
Nov-09	10.3	10.7
Dec-09	4.8	7.4
Jan-10	3.1	6.2
Feb-10	2.1	5.6
Mar-10	5.6	6.8
Apr-10	8.2	8.6
May-10	10.1	10.1
Jun-10	14.4	12.8

Chart showing record result of the temperature difference before and after Ground-Air Heat Exchanger was fitted

Date 04/01/2010	Temperature °C after	Temperature °C before
11.00hrs	4	-15



